

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 5276-0899:0123

Page 1 of 1

CATEGORY: 5276 -- CARBON MONOXIDE ALARMS

LISTEE: Universal Security Instruments 11407-A Cronhill Dr., Owings Mills, MD 21117
Contact: Stephen Babinec (410) 363-3000 Ext: 214 Fax (410) 363-2218
Email: steveb@universalsecurity.com

DESIGN: Models "Universal Security" MC304S, MCD305S, *MCGD305S; "Safety Sentry" ESD006SB and "USI Electric" MC504S, MCD505S Single Station Carbon Monoxide Alarms with 10 year sealed batteries. Models MCD305S, *MCGD305S and MCD505S have a visual display. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 3 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes, NFPA 720, and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Trade name "USI Electric", "Safety Sentry", model number, electrical rating, and ETL label.

APPROVAL: Listed as single station Carbon Monoxide alarms for indoor residential applications. Refer to listee's Installation Instructions Manual for details.

NOTE: Carbon Monoxide alarms are not intended/suitable for fire and smoke detection.

*Rev 07-11-17 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division